

## Schedule 2 – Occupier’s statement<sup>1</sup>

Name of building and address: 12 King Street Caboolture Qld 4510	Name of occupier: Various		
Prescribed fire safety installation <sup>2</sup>	Nominated Australian Standard or relevant maintenance requirements <sup>3</sup>	Was a <i>critical defect notice</i> <sup>4</sup> issued during the period covered by this statement (Yes/No)	Date of rectification of <i>critical defect</i> <sup>4</sup>
Air handling systems	N/A		
Emergency lifts	N/A		
Emergency lighting	AS2293.1	NO	
Emergency power supply	N/A		
Emergency warning and intercommunication systems <sup>5</sup>	AS1851-8	NO	
Exit signs	AS2293	NO	
Fire detection and alarm systems	AS1851-6	NO	
Fire doorsets	N/A		
Fire extinguishers	AS1851-10	NO	
Fire hose reels	AS1851-9	NO	
Fire hydrants (including boosters)	AS1851-4	NO	
Fire mains	AS1851-4	NO	
Fire shutters	N/A		
Other features <sup>6</sup> (provide details)	N/A		
Smoke and heat venting systems	N/A		
Smoke doorsets	N/A		
Smoke exhaust systems	N/A		
Solid core doors	N/A		
Special automatic fire suppression systems	N/A		
Sprinklers	AS1851-2	NO	
Stairwell pressurisation systems	N/A		

I, **Sally Collins** as an authorised person on behalf of **Wylie Creek and Cryton Investments P/L**<sup>7</sup> declare the above listed *prescribed fire safety installations* have  
(Full name) (Name of organisation)

been *maintained* during the period covered by this statement in accordance with this code and as specified,  on 8<sup>th</sup> February 2022  
(Signature) (Date)

1. This yearly statement must be kept with the building’s *maintenance records* in accordance with A2(c) and be produced on demand by local government officers and authorised officers of the Queensland Fire and Rescue Service.
2. Note: delete *prescribed fire safety installations* that are not installed in/for the building.
3. For example, in accordance with manufacturer’s instruction manual date day/month/year or in accordance with the building’s *certificate of classification*.
4. Copies of *critical defect notices* issued and proof of rectification within the period of this statement must be attached.
5. This is also known as sound systems and intercommunication systems for emergency purposes.
6. Includes additional *fire safety installations* or conditions that are *required* under the building’s *alternative solution* of the *Building Act 1975* or *BCA* clauses E1.10 and E2.3.
7. If the owner is signing or the *occupier* is not employed by a body corporate the ‘name of organisation’ section does not need to be completed.